


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE.**

No. 01 (प्रयोगशाळा)

Date: 17/03/2023

It is certified that an inspection team headed by JITENDRA LAKRA
ASSISTANT ENGINEER, DRINKING WATER AND SANITATION
SUB-Div. GUMLA (Name of Officers with designation) from D.W &
S. Div. GUMLA (Name of Department / Office) inspected the
School Name - **S.S+2 HS GUMLA (20160806203)**, Village - **GUMLA**, Block -
GUMLA, District - **GUMLA**, Pin - **835211, Jharkhand** on 15.03.2023. (Date)
and found that the **S.S+2 HS GUMLA** has safe drinking water facilities for the
students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per the norms prescribed
by the Central/State/U.T Govt.


The above valid for a period of one year

Signature with Seal:  15/03/2023

Name : JITENDRA LAKRA

Designation : ASSITANT ENGINEER

Assistant Engineer
D W & S Sub Division Gumla-II

 15/03/2023
प्र० प्रधानाध्यापक
एस० एस०+२ उच्च विद्यालय
Principal,
S.S+2 HS GUMLA,
GUMLA, GUMLA, GUMLA,
Pin - 835211, Jharkhand.



Drinking Water and Sanitation Division, Gumla

District Level Water Testing Laboratory, Gumla

Name of Customer/Institution :-	एस. एस. +2 उच्च वि. गुमला
Address of Customer/Institution :-	Block :- गुमला
	Panchayat :- गुमला
	Village :- गुमला
Sample Collector :-	अजित मुषाणा वाडा
Type of Source :-	चापाकल
Date of Sample Collection :-	22/02/2022
Date of Analysis :-	22/02/2022

Report

Sl. No.	Parameter	Unit	Acceptable Limit	Permissible Limit	Result	Remarks
1	TDS	Mg/L	500	2000	756	
2	Chloride	Mg/L	250	1000	166	
3	Alkanity	Mg/L	200	600	124	
4	Total Hardness	Mg/L	200	600	340	
5	Calcium as a CaCo3	Mg/L	75	200	84.8	
6	Magnesium as a CaCo3	Mg/L	30	75	51.51	
7	PH		6.5	8.5	8.31	

Rajesh
22-02-2022

Chemist
Gumla

Shree
22/2/2022
Nodel Officer
Gumla

Assistant Engineer
Drinking Water & Sanitation
Sub-division No-II Gumla